



# ELECTROMUNDO

COLEGIO DE INGENIEROS ELECTRICISTAS Y ELECTRONICOS LA PAZ - BOLIVIA No 44 - MARZO - 2005

Edición  
especial

# 25

de: Miguel  
1 Prof. Durani  
02102 8:00



# Aniversario

CIEE - La Paz

DISTRIBUCION GRATUITA

## VOLT AND VAR SIMULTANEOUS CONTROL IN DISTRIBUTION SYSTEMS

Miguel Edgar Morales Udaeta

Geraldo Francisco Burani

José Aquiles Baesso Grimoni

Renán Jorge Orellana Lafuente

(SEGUNDA PARTE)

---

### ABSTRACT

The main goal of this work is to minimize the Energy and Peak Power losses, so that the voltage is within a normal gap all the time by varying load state, and the capacitors nonlinear cost are taken into account: These bring up the necessity of simultaneous Volt's control. For this, the general matter of capacitive compensation in distribution guides to one realistic form, with lateral branches taken for a real physic modeling. By the analysis of compensation, an intrinsic couple situation of the reactive current flow and the voltage variations along the feeder all the time is regarded. The result of the analytic address gives a decoupled solution, which implicated into two problems: the capacitor; one (Var compensation), concerning its locations, sizes and control; and the regulator one (to provide smooth Voltage profile), concerning its locations and control. Then, a computational program systematization in based in this approach is developed to solve the problem, through the division of the global problem into smaller problems. Once conquered those, better quality and bigger efficiency will be brought in the distribution system focusing Distribution Automation.

Key words: Var Control, Volt Control, Distribution System; Energy Saving; Capacitor; Efficiency.